

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

**System Name** City of Dayton **PWS #** 4100252  
**Month/Year** Dec-21 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	8:12	WTP - A1	0.80	
2	7:19		0.78	
3	7:06		0.79	
4	7:01		0.78	
5	7:28		0.85	
6	9:30		0.84	
7	8:11		0.86	
8	7:55		0.90	
9	8:18		0.86	
10	7:47		0.87	
11	8:54		0.81	
12	7:05		0.87	
13	7:26		0.79	
14	6:40		0.80	
15	7:06		0.86	
16	6:45		0.78	
17	7:01		0.87	
18	9:20		0.81	
19	8:31		0.81	
20	7:34		1.13	
21	8:21		1.30	
22	9:01		1.42	
23	8:01		1.37	
24	7:44		0.85	
25	6:45		0.84	
26	8:45		0.85	
27	8:19		0.86	
28	7:00		0.85	
29	7:35		0.85	
30	7:04		0.80	
31	7:05	WTP - A1	0.85	

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L  NO  
 If yes, what was the longest time period until the required level was restored \_\_\_\_ hours - if > 4 hours,  
 Drinking Water Program to be notified by end of next business day

**GWS Servin 3,300 or Fewer**  
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO  
*Attach those results and submit them with this form*

--	--

**Printed Name** Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

**Signature** *Stephen Sagmiller*

**Date** \_\_\_\_ 1/3/2021