

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Feb-21 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	8:08	WTP - A1		1.01
2	8:30			1.13
3	8:25			0.86
4	8:22			0.85
5	8:34			0.70
6	7:55			0.84
7	7:36			0.86
8	8:54			0.87
9	8:36			0.69
10	8:29			0.68
11	8:52			0.63
12	8:51			0.82
13	6:40			1.05
14	7:00			0.86
15	7:30			0.77
16	7:23			0.83
17	8:19			0.79
18	8:56			1.00
19	8:16			0.94
20	7:25			0.91
21	7:35			0.90
22	9:12			0.86
23	9:18			0.91
24	9:30			0.95
25	8:17			0.97
26	8:26			0.93
27	7:13			0.97
28	7:09			0.99
		WTP - A1		

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 3/2/2021