

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton PWS # 4100252  
 Month/Year Mar-21 Entry Point WTP - A1 Required Minimum Residual 0.6 mg/L

Lowest free chlorine residual at entry point to distribution				
Date	Time	Source in Use	system	Notes
1	7:31	WTP - A1		1.01
2	7:27			1.01
3	7:50			1.03
4	7:02			0.99
5	8:00			0.93
6	10:30			0.84
7	9:37			0.89
8	9:29			0.85
9	8:19			0.85
10	8:42			0.85
11	8:38			0.94
12	9:00			0.96
13	7:26			0.77
14	7:45			0.77
15	8:38			0.75
16	8:14			0.81
17	8:23			0.78
18	8:26			0.76
19	8:47			0.85
20	6:57			0.87
21	10:18			0.89
22	7:29			0.84
23	8:30			0.86
24	8:40			0.92
25	8:50			0.90
26	9:00			0.93
27	7:23			0.94
28	7:32			0.96
29	8:18			0.93
30	11:37			0.96
31	8:30	WTP - A1		0.85

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L  NO  
 If yes, what was the longest time period until the required level was restored \_\_\_\_ hours - if > 4 hours,  
 Drinking Water Program to be notified by end of next buisness day

**GWS Servin 3,300 or Fewer**  
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO  
*Attach those results and submit them with this form*

**Printed Name** Stephen Sagmiller **Title**Public Works Director **Operator Certification #** 6845

**Signature** *Stephen Sagmiller*

**Date** \_\_\_\_ 4/5/2021