

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

**System Name** City of Dayton **PWS #** 4100252  
**Month/Year** Apr-21 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	8:10	WTP - A1		0.96
2	8:48			0.89
3	11:15			0.95
4	10:52			0.87
5	9:31			0.92
6	8:29			0.91
7	8:50			0.94
8	7:40			0.90
9	8:16			0.99
10	8:50			0.93
11	7:48			0.95
12	8:26			0.88
13	8:21			0.95
14	7:51			0.86
15	8:40			0.91
16	8:52			0.83
17	7:49			0.90
18	7:44			0.82
19	8:45			0.87
20	8:53			0.83
21	8:26			0.86
22	8:52			0.84
23	6:28			0.87
24	7:30			0.79
25	7:40			0.86
26	8:50			0.92
27	8:30			0.84
28	9:25			0.79
29	12:44			0.84
30	8:38			0.75
		WTP - A1		

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L  NO  
 If yes, what was the longest time period until the required level was restored \_\_\_\_ hours - if > 4 hours,  
 Drinking Water Program to be notified by end of next business day

**GWS Servin 3,300 or Fewer**  
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO  
*Attach those results and submit them with this form*

--

**Printed Name** Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

**Signature** *Stephen Sagmiller*

**Date** \_\_\_\_ 5/4/2021