

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year May-21 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	8:41	WTP - A1	0.81	
2	9:12		0.72	
3	8:40		0.80	
4	8:30		0.81	
5	8:20		0.80	
6	8:30		0.90	
7	8:34		1.18	
8	8:32		0.80	
9	7:50		0.86	
10	8:14		0.70	
11	8:12		0.72	
12	8:34		0.86	
13	8:18		0.83	
14	8:37		0.85	
15	7:35		0.87	
16	7:43		0.85	
17	7:10		0.84	
18	7:07		0.84	
19	7:15		0.82	
20	8:15		0.84	
21	9:26		0.84	
22	8:34		0.83	
23	8:13		0.85	
24	8:10		0.86	
25	7:38		0.85	
26	8:22		0.83	
27	8:13		0.84	
28	8:06		0.84	
29	7:50		0.84	
30	7:55		0.84	
31	8:03	WTP - A1	0.88	

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

--

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 6/1/2021