

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Jun-21 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	7:22	WTP - A1	0.84	
2	7:14		0.88	
3	7:21		0.86	
4	8:08		0.83	
5	7:42		0.85	
6	7:44		0.83	
7	7:22		0.84	
8	7:11		0.83	
9	7:13		0.86	
10	7:12		0.84	
11	10:25		0.85	
12	7:54		0.84	
13	7:55		0.86	
14	8:59		0.84	
15	9:12		0.84	
16	8:21		0.86	
17	8:19		0.94	
18	7:43		1.01	
19	7:35		0.95	
20	7:58		0.89	
21	8:15		0.94	
22	8:49		0.85	
23	8:25		0.98	
24	9:20		0.97	
25	7:40		0.91	
26	6:40		0.92	
27	7:30		0.96	
28	8:40		0.89	
29	8:58		0.93	
30	8:49		0.93	
		WTP - A1		

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 7/6/2021