

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

**System Name** City of Dayton **PWS #** 4100252  
**Month/Year** Jul-21 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	8:32	WTP - A1	0.85	
2	8:29		0.85	
3	7:49		0.84	
4	7:34		0.85	
5	7:51		0.86	
6	8:50		0.84	
7	8:26		0.87	
8	8:31		0.87	
9	8:30		0.87	
10	6:51		0.86	
11	8:33		0.86	
12	7:32		0.84	
13	8:30		0.85	
14	8:24		0.86	
15	7:44		0.85	
16	8:26		0.83	
17	7:00		0.85	
18	7:00		0.84	
19	7:20		0.83	
20	7:35		0.84	
21	8:22		0.84	
22	8:27		0.83	
23	9:03		0.85	
24	7:48		0.87	
25	7:18		0.87	
26	7:11		0.85	
27	7:19		0.84	
28	8:20		0.81	
29	9:00		0.79	
30	8:30		0.81	
31	6:52	WTP - A1	0.84	

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L  NO  
 If yes, what was the longest time period until the required level was restored \_\_\_\_ hours - if > 4 hours,  
 Drinking Water Program to be notified by end of next business day

**GWS Servin 3,300 or Fewer**  
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO  
 Attach those results and submit them with this form

--

**Printed Name** Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

**Signature** *Stephen Sagmiller*

**Date** \_\_\_\_ 8/2/2021