

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton PWS # 4100252
 Month/Year Oct-21 Entry Point WTP - A1 Required Minimum Residual 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	8:50	WTP - A1		0.77
2	7:47			0.80
3	7:42			0.76
4	7:19			0.77
5	7:19			0.78
6	7:17			0.76
7	7:22			0.84
8	8:26			0.84
9	7:50			0.76
10	7:30			0.76
11	7:40			0.78
12	9:00			0.75
13	8:46			0.75
14	8:35			0.75
15	8:49			0.86
16	9:20			0.85
17	8:05			0.83
18	7:28			0.84
19	7:33			0.84
20	10:12			0.84
21	9:08			0.83
22	9:10			0.83
23	8:28			0.87
24	8:04			0.86
25	7:39			0.85
26	8:26			0.83
27	8:44			0.84
28	8:19			0.82
29	8:20			0.80
30	7:50			0.85
31	7:55	WTP - A1		0.81

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
 Attach those results and submit them with this form

--

Printed Name Stephen Sagmiller Title Public Works Director Operator Certification # 6845

Signature *Stephen Sagmiller*

Date ____ 11/2/2021