

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Nov-21 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	7:33	WTP - A1	0.81	
2	7:17		0.84	
3	7:17		0.80	
4	7:24		0.82	
5	8:18		0.85	
6	7:50		1.22	
7	7:30		0.89	
8	8:28		0.91	
9	8:29		0.87	
10	8:51		0.87	
11	5:17		0.91	
12	8:30		0.85	
13	7:42		0.86	
14	7:51		0.84	
15	8:35		1.05	
16	8:38		1.06	
17	8:44		0.77	
18	8:28		0.76	
19	8:31		1.10	
20	7:54		0.86	
21	6:52		0.85	
22	7:37		0.85	
23	8:35		0.85	
24	7:29		0.84	
25	7:04		0.84	
26	7:43		0.77	
27	7:29		0.74	
28	7:48		0.73	
29	7:12		0.76	
30	7:16		0.76	
		WTP - A1		

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

--	--

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 12/6/2021