

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

**System Name** City of Dayton **PWS #** 4100252  
**Month/Year** Dec-21 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	7:19	WTP - A1		0.76
2	7:12			0.77
3	8:33			0.88
4	6:45			0.85
5	6:37			0.85
6	7:29			0.83
7	7:22			0.88
8	7:28			0.85
9	7:28			0.86
10	8:39			0.63
11	7:00			0.78
12	7:40			0.84
13	7:41			0.86
14	7:30			0.88
15	7:40			0.89
16	7:32			0.88
17	8:42			0.88
18	8:07			0.87
19	7:50			0.86
20	8:49			0.88
21	6:48			0.99
22	8:30			0.89
23	8:32			0.95
24	7:00			0.94
25	7:39			0.95
26	8:22			0.95
27	9:40			0.95
28	7:23			0.94
29	1:18			0.42
30	7:17			1.02
31	8:46	WTP - A1		0.87

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L  NO  
 If yes, what was the longest time period until the required level was restored \_\_\_\_ hours - if > 4 hours,  
 Drinking Water Program to be notified by end of next business day

**GWS Servin 3,300 or Fewer**  
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO  
 Attach those results and submit them with this form

--

**Printed Name** Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

**Signature** *Stephen Sagmiller*

**Date** \_\_\_\_ 1/3/2022