

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

**System Name** City of Dayton **PWS #** 4100252  
**Month/Year** Jan-22 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	9:01	WTP - A1		0.84
2	8:11			0.88
3	7:31			0.85
4	7:37			0.81
5	7:40			0.84
6	8:24			0.82
7	9:15			0.77
8	7:54			0.82
9	7:54			0.82
10	7:18			0.81
11	7:31			0.82
12	7:12			0.83
13	7:12			0.81
14	8:50			0.77
15	8:06			0.85
16	8:20			0.86
17	9:10			0.85
18	7:26			0.86
19	8:50			0.88
20	7:16			0.87
21	8:50			0.85
22	7:30			0.85
23	7:50			0.85
24	7:30			0.85
25	8:30			0.85
26	7:30			0.85
27	7:30			0.85
28	9:29			0.85
29	8:40			0.86
30	7:27			0.87
31	7:47	WTP - A1		0.85

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L  NO  
 If yes, what was the longest time period until the required level was restored \_\_\_\_ hours - if > 4 hours,  
 Drinking Water Program to be notified by end of next business day

**GWS Servin 3,300 or Fewer**  
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO  
 Attach those results and submit them with this form

--

**Printed Name** Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

**Signature** *Stephen Sagmiller*

**Date** \_\_\_\_ 2/1/2022