

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Feb-22 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

| Lowest free chlorine residual at entry point to distribution system | | | | |
|---------------------------------------------------------------------|------|---------------|--------|-------|
| Date | Time | Source in Use | system | Notes |
| 1 | 7:43 | WTP - A1 | | 0.86 |
| 2 | 7:55 | | | 0.88 |
| 3 | 7:51 | | | 0.84 |
| 4 | 8:39 | | | 0.96 |
| 5 | 7:52 | | | 0.85 |
| 6 | 7:46 | | | 0.80 |
| 7 | 7:22 | | | 0.80 |
| 8 | 7:27 | | | 0.80 |
| 9 | 7:34 | | | 0.79 |
| 10 | 7:30 | | | 0.83 |
| 11 | 8:40 | | | 0.84 |
| 12 | 7:00 | | | 0.84 |
| 13 | 7:20 | | | 0.84 |
| 14 | 7:30 | | | 0.86 |
| 15 | 9:23 | | | 0.84 |
| 16 | 9:14 | | | 0.85 |
| 17 | 9:18 | | | 0.94 |
| 18 | 8:57 | | | 0.92 |
| 19 | 7:43 | | | 0.81 |
| 20 | 8:03 | | | 0.85 |
| 21 | 7:52 | | | 0.86 |
| 22 | 9:14 | | | 0.74 |
| 23 | 7:41 | | | 0.88 |
| 24 | 8:34 | | | 0.86 |
| 25 | 8:59 | | | 0.87 |
| 26 | 7:49 | | | 0.87 |
| 27 | 7:37 | | | 0.85 |
| 28 | 7:00 | | | 0.85 |
| | | | | |
| | | | | |
| | | WTP - A1 | | |

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

| |
|--|
| |
|--|

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 3/2/2022