

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

**System Name** City of Dayton **PWS #** 4100252  
**Month/Year** Mar-22 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	8:51	WTP - A1		0.95
2	8:28			1.01
3	9:00			1.01
4	8:39			1.00
5	7:47			0.84
6	7:44			0.78
7	7:16			0.84
8	7:15			0.82
9	7:33			0.78
10	7:16			0.79
11	8:36			0.80
12	6:30			0.81
13	8:00			0.86
14	8:57			0.78
15	8:22			0.77
16	8:38			0.82
17	8:28			0.82
18	8:53			0.82
19	7:56			0.76
20	8:15			0.79
21	7:39			0.78
22	7:47			0.80
23	7:29			0.88
24	7:46			0.81
25	8:40			0.83
26	7:43			0.81
27	7:53			0.81
28	7:46			0.80
29	7:41			0.77
30	7:36			0.78
31	7:39	WTP - A1		0.77

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L  NO  
 If yes, what was the longest time period until the required level was restored \_\_\_\_ hours - if > 4 hours,  
 Drinking Water Program to be notified by end of next business day

**GWS Servin 3,300 or Fewer**  
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO  
*Attach those results and submit them with this form*

--

**Printed Name** Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

**Signature** *Stephen Sagmiller*

**Date** \_\_\_\_ 3/1/2022