

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Apr-22 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	8:26	WTP - A1		0.77
2	7:50			0.73
3	8:00			0.78
4	7:30			0.78
5	7:30			0.72
6	7:30			0.78
7	7:30			0.73
8	8:46			0.79
9	8:15			0.84
10	8:12			0.84
11	7:24			0.78
12	7:33			0.87
13	7:24			0.86
14	7:29			0.86
15	8:41			0.85
16	7:43			0.90
17	7:48			0.89
18	7:36			0.85
19	7:51			0.87
20	7:36			0.86
21	7:37			0.80
22	8:38			0.85
23	7:03			0.86
24	7:12			0.82
25	7:53			0.87
26	1:13			0.85
27	7:16			0.84
28	7:26			0.85
29	8:41			0.83
30	7:50			0.81
		WTP - A1		

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
 Attach those results and submit them with this form

--

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 5/2/2022