

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Jun-22 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	7:41	WTP - A1		0.85
2	7:43			0.89
3	8:00			0.85
4	8:00			0.85
5	7:20			1.00
6	7:30			0.94
7	7:20			0.85
8	9:17			0.85
9	9:06			0.84
10	8:49			0.82
11	6:52			0.84
12	6:58			0.85
13	7:19			0.88
14	7:18			0.83
15	7:20			0.78
16	7:21			0.87
17	8:30			0.89
18	8:05			0.86
19	8:37			0.91
20	8:07			0.85
21	8:34			0.85
22	7:12			0.84
23	7:09			0.81
24	8:33			0.81
25	7:53			0.77
26	7:54			0.77
27	8:40			0.90
28	8:10			0.83
29	8:40			0.88
30	8:30			0.80
		WTP - A1		

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
 Attach those results and submit them with this form

--

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 7/5/2022