

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Jul-22 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	7:00	WTP - A1		0.85
2	6:50			0.89
3	7:30			0.87
4	7:15			1.00
5	9:00			0.85
6	9:20			0.85
7	8:24			0.86
8	8:56			1.04
9	8:10			1.00
10	7:56			1.02
11	7:53			0.99
12	9:13			0.99
13	7:34			0.96
14	8:25			0.79
15	9:25			0.83
16	7:14			0.75
17	7:03			0.78
18	7:32			0.67
19	7:26			0.65
20	7:20			0.76
21	7:18			0.75
22	9:07			0.87
23	8:05			0.75
24	8:03			0.75
25	7:29			0.71
26	7:28			0.73
27	5:45			0.71
28	7:33			0.69
29	8:31			0.86
30	6:10			0.85
31	7:40	WTP - A1		0.85

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

--

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 8/1/2022