

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Aug-22 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	8:35	WTP - A1		0.86
2	9:34			0.83
3	7:20			0.82
4	7:40			0.84
5	9:12			0.84
6	8:04			0.82
7	7:12			0.81
8	7:37			0.84
9	7:41			0.80
10	7:37			0.79
11	7:38			0.81
12	8:36			0.83
13	6:51			0.82
14	6:42			0.79
15	7:08			0.77
16	8:42			0.85
17	7:18			0.84
18	7:12			0.81
19	8:47			0.87
20	7:59			0.83
21	7:51			0.89
22	7:32			0.76
23	7:33			0.95
24	7:37			0.94
25	7:40			0.95
26	7:50			0.82
27	7:50			0.86
28	7:48			0.81
29	7:48			0.81
30	7:30			0.87
31	8:36	WTP - A1		0.87

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

--	--

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 9/6/2022