

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Sep-22 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

| Lowest free chlorine residual at entry point to distribution system | | | | |
|---|------|---------------|--------|-------|
| Date | Time | Source in Use | system | Notes |
| 1 | 7:36 | WTP - A1 | | 0.86 |
| 2 | 8:37 | | | 0.86 |
| 3 | 7:46 | | | 0.86 |
| 4 | 7:49 | | | 0.91 |
| 5 | 8:16 | | | 0.87 |
| 6 | 8:20 | | | 0.89 |
| 7 | 8:20 | | | 0.85 |
| 8 | 7:46 | | | 0.85 |
| 9 | 9:00 | | | 0.85 |
| 10 | 6:55 | | | 0.89 |
| 11 | 6:40 | | | 0.90 |
| 12 | 7:10 | | | 0.88 |
| 13 | 7:10 | | | 0.89 |
| 14 | 7:20 | | | 0.88 |
| 15 | 7:25 | | | 0.88 |
| 16 | 8:53 | | | 0.89 |
| 17 | 7:53 | | | 0.89 |
| 18 | 7:46 | | | 0.89 |
| 19 | 7:38 | | | 0.88 |
| 20 | 8:37 | | | 0.86 |
| 21 | 7:39 | | | 0.84 |
| 22 | 7:31 | | | 0.86 |
| 23 | 9:39 | | | 0.83 |
| 24 | 7:20 | | | 0.86 |
| 25 | 7:10 | | | 0.89 |
| 26 | 7:30 | | | 0.84 |
| 27 | 7:40 | | | 0.85 |
| 28 | 7:30 | | | 0.88 |
| 29 | 7:40 | | | 0.84 |
| 30 | 8:33 | | | 0.86 |
| | | WTP - A1 | | |

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 10/5/2022