

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

**System Name** City of Dayton **PWS #** 4100252  
**Month/Year** Oct-22 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	7:55	WTP - A1	0.88	
2	8:07		0.84	
3	7:36		0.87	
4	7:41		0.83	
5	8:47		0.85	
6	7:40		0.86	
7	9:28		0.88	
8	6:38		0.85	
9	6:44		0.86	
10	7:05		0.85	
11	7:05		0.90	
12	7:12		0.86	
13	7:13		0.84	
14	8:44		0.90	
15	7:48		0.90	
16	7:46		0.89	
17	7:37		0.85	
18	7:30		0.60	
19	7:48		0.74	
20	9:20		0.84	
21	9:20		0.84	
22	7:20		0.90	
23	7:30		0.90	
24	7:40		0.87	
25	8:10		0.83	
26	7:40		0.85	
27	7:40		0.84	
28	8:56		0.97	
29	8:41		0.70	
30	8:37		0.88	
31	7:49	WTP - A1	0.83	

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L  NO  
 If yes, what was the longest time period until the required level was restored \_\_\_\_ hours - if > 4 hours,  
 Drinking Water Program to be notified by end of next business day

**GWS Servin 3,300 or Fewer**  
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO  
*Attach those results and submit them with this form*

**Printed Name** Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

**Signature** *Stephen Sagmiller*

**Date** \_\_\_\_ 11/2/2022