

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Nov-22 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	7:49	WTP - A1		0.70
2	8:44			0.86
3	8:36			1.04
4	8:28			0.85
5	7:00			0.94
6	7:01			0.95
7	7:15			0.90
8	7:10			0.89
9	7:05			0.91
10	7:15			0.90
11	8:08			0.89
12	8:03			0.90
13	7:54			0.88
14	7:32			0.87
15	7:29			0.86
16	7:32			0.86
17	7:29			0.86
18	8:38			0.85
19	7:50			0.80
20	8:00			0.86
21	7:30			0.81
22	7:30			0.81
23	8:56			0.85
24	7:40			0.85
25	8:28			0.77
26	8:27			0.78
27	7:43			0.79
28	7:45			0.80
29	7:55			0.79
30	7:55			0.79
		WTP - A1		

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 12/1/2022