

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

**System Name** City of Dayton **PWS #** 4100252  
**Month/Year** Dec-22 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	7:52	WTP - A1		0.87
2	8:58			0.83
3	7:15			0.84
4	6:50			0.83
5	7:12			0.82
6	7:16			0.81
7	7:18			0.83
8	7:15			0.79
9	8:33			0.88
10	7:25			0.90
11	4:34			0.91
12	7:34			0.91
13	7:40			0.90
14	7:34			0.91
15	7:38			0.89
16	8:48			0.89
17	7:20			0.89
18	8:00			0.80
19	7:30			0.80
20	7:30			0.67
21	7:30			0.78
22	8:53			0.80
23	8:02			0.79
24	8:00			0.78
25	8:18			0.78
26	8:28			0.80
27	8:40			0.73
28	7:40			0.98
29	9:00			1.00
30	9:04			1.04
31	6:35	WTP - A1		0.82

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L  NO  
 If yes, what was the longest time period until the required level was restored \_\_\_\_ hours - if > 4 hours,  
 Drinking Water Program to be notified by end of next business day

**GWS Servin 3,300 or Fewer**  
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO  
*Attach those results and submit them with this form*

--

**Printed Name** Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

**Signature** *Stephen Sagmiller*

**Date** \_\_\_\_ 1/4/2023