

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Feb-23 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	8:03	WTP - A1		0.80
2	7:48			0.81
3	8:34			0.78
4	7:52			0.84
5	7:54			0.81
6	7:44			0.77
7	7:30			0.80
8	7:33			0.85
9	7:22			0.81
10	8:43			0.81
11	8:20			0.82
12	7:58			0.82
13	7:28			0.80
14	7:30			0.83
15	7:31			0.83
16	8:00			0.84
17	8:37			0.84
18	6:29			0.86
19	6:38			0.85
20	5:53			0.82
21	7:11			0.81
22	7:12			0.84
23	7:09			0.87
24	8:35			0.86
25	8:29			0.82
26	7:45			0.82
27	7:42			0.83
28	7:52			0.86
		WTP - A1		

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 3/2/2023