

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Mar-23 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	7:49	WTP - A1	0.87	
2	7:56		0.88	
3	8:21		0.88	
4	7:05		0.86	
5	7:50		0.84	
6	7:30		0.84	
7	7:20		0.87	
8	7:25		0.82	
9	7:25		0.84	
10	8:37		0.85	
11	7:48		0.89	
12	7:10		0.89	
13	7:45		0.89	
14	7:50		1.00	
15	7:40		1.02	
16	7:25		1.00	
17	8:30		0.83	
18	7:53		0.73	
19	8:45		0.69	
20	7:58		0.69	
21	7:35		0.69	
22	8:20		0.67	
23	7:47		0.65	
24	8:30		0.86	
25	7:33		0.84	
26	7:32		0.87	
27	7:33		0.79	
28	8:25		0.79	
29	8:28		0.78	
30	8:14		0.81	
31	8:29	WTP - A1	0.83	

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 4/4/2023