

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Apr-23 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	8:07	WTP - A1		0.72
2	8:02			0.71
3	7:58			0.71
4	7:56			0.66
5	7:47			0.82
6	8:38			0.79
7	9:50			0.82
8	6:47			0.83
9	6:40			0.82
10	6:50			0.82
11	7:00			0.79
12	7:08			0.81
13	7:08			0.81
14	8:31			0.77
15	7:59			0.78
16	8:13			0.77
17	8:35			0.75
18	8:16			0.86
19	7:23			0.71
20	7:44			0.7
21	8:25			0.82
22	6:50			0.82
23	7:00			0.73
24	8:22			0.82
25	9:30			0.8
26	8:30			0.82
27	8:25			0.84
28	8:35			0.8
29	8:09			0.84
30	8:26			0.83
		WTP - A1		

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
 Attach those results and submit them with this form

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 5/3/2023