

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

**System Name** City of Dayton **PWS #** 4100252  
**Month/Year** May-23 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	8:05	WTP - A1		0.83
2	10:15			0.80
3	8:42			0.80
4	9:04			0.86
5	8:35			0.83
6	7:28			0.83
7	7:45			0.81
8	9:43			0.82
9	8:10			0.84
10	8:18			0.83
11	8:29			0.84
12	8:27			0.82
13	7:19			0.85
14	7:02			0.84
15	8:30			0.82
16	8:54			0.82
17	7:12			0.83
18	8:14			0.82
19	6:58			0.79
20	6:04			0.79
21	7:17			0.82
22	7:35			0.82
23	7:21			0.82
24	7:35			0.83
25	7:35			0.82
26	8:25			0.78
27	8:18			0.81
28	7:57			0.82
29	8:27			0.76
30	8:50			0.80
31	8:32	WTP - A1		0.82

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L  NO  
 If yes, what was the longest time period until the required level was restored \_\_\_\_ hours - if > 4 hours,  
 Drinking Water Program to be notified by end of next business day

**GWS Servin 3,300 or Fewer**  
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO  
*Attach those results and submit them with this form*

--	--

**Printed Name** Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

**Signature** *Stephen Sagmiller*

**Date** \_\_\_\_ 6/1/2023