

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton PWS # 4100252
 Month/Year Sep-23 Entry Point WTP - A1 Required Minimum Residual 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	8:45	WTP - A1		0.83
2	7:15			0.80
3	8:07			0.84
4	7:00			0.85
5	7:40			0.80
6	7:30			0.80
7	7:35			0.83
8	8:00			0.82
9	9:42			0.82
10	8:39			0.82
11	7:53			0.82
12	7:18			0.82
13	7:38			0.82
14	7:28			0.82
15	9:14			0.80
16	8:25			0.78
17	8:27			0.78
18	9:58			0.79
19	8:15			0.82
20	8:30			0.82
21	7:45			0.83
22	8:45			0.82
23	8:15			0.84
24	8:20			0.80
25	7:55			0.82
26	7:40			0.82
27	7:41			0.82
28	7:42			0.81
29	9:50			0.79
30	6:25			0.84
		WTP - A1		

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
 Attach those results and submit them with this form

Printed Name Stephen Sagmiller Title Public Works Director Operator Certification # 6845

Signature *Stephen Sagmiller*

Date ____ 10/2/2023