

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Oct-23 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	6:28	WTP - A1		0.80
2	9:00			0.81
3	8:22			0.83
4	7:06			0.81
5	7:12			0.82
6	8:40			0.82
7	10:19			0.82
8	9:48			0.82
9	7:33			0.82
10	7:23			0.82
11	7:24			0.82
12	7:26			0.82
13	9:00			0.82
14	6:42			0.82
15	6:40			0.82
16	7:19			0.82
17	8:25			0.82
18	8:55			0.82
19	8:45			0.75
20	9:40			0.75
21	8:30			0.81
22	9:20			0.84
23	7:20			0.83
24	7:30			0.79
25	8:25			0.73
26	8:20			0.82
27	8:45			0.82
28	6:15			0.84
29	6:38			0.81
30	8:45			0.82
31	9:00	WTP - A1		0.82

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 11/2/2023