

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Nov-23 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	7:09	WTP - A1		0.82
2	8:30			0.82
3	8:25			0.82
4	7:58			0.74
5	7:54			0.74
6	8:55			0.74
7	6:45			0.81
8	8:25			0.82
9	8:35			0.84
10	6:52			0.82
11	9:11			0.82
12	7:32			0.82
13	7:08			0.82
14	7:24			0.82
15	7:40			0.82
16	7:39			0.82
17	7:31			0.78
18	7:10			0.81
19	7:50			0.81
20	7:40			0.8
21	7:45			0.84
22	7:25			0.82
23	6:40			0.85
24	8:08			0.75
25	7:58			0.73
26	8:17			0.73
27	6:51			0.79
28	7:17			0.75
29	7:12			0.76
30	10:12			0.77
		WTP - A1		

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 12/4/2023