

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Dec-23 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	6:40	WTP - A1		0.78
2	8:16			0.75
3	8:26			0.82
4	7:32			0.82
5	8:20			0.82
6	8:20			0.82
7	7:36			0.82
8	8:56			0.91
9	8:05			0.90
10	8:40			0.91
11	8:25			0.91
12	7:20			0.90
13	7:24			0.90
14	7:20			0.83
15	7:50			0.81
16	7:40			0.83
17	7:50			0.84
18	8:33			0.85
19	7:45			0.81
20	7:50			0.85
21	7:45			0.82
22	8:15			0.83
23	7:16			0.84
24	7:06			0.82
25	5:52			0.81
26	7:56			0.77
27	7:30			0.82
28	8:30			0.82
29	6:45			0.82
30	7:35			0.82
31	7:37	WTP - A1		0.82

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 1/2/2024