

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

**System Name** City of Dayton **PWS #** 4100252  
**Month/Year** Jan-24 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	7:26	WTP - A1	0.82	
2	7:26		0.82	
3	7:33		0.82	
4	7:52		0.82	
5	7:15		0.85	
6	8:22		0.87	
7	8:00		0.93	
8	8:59		0.82	
9	8:43		0.82	
10	8:51		0.83	
11	8:45		0.83	
12	9:05		0.82	
13	11:59		0.79	
14	8:45		0.84	
15	11:45		1.13	
16	8:40		0.81	
17	8:44		0.82	
18	1:10		0.83	
19	7:43		0.65	
20	8:10		0.82	
21	8:10		0.82	
22	7:10		0.82	
23	7:05		0.82	
24	7:10		0.88	
25	7:10		0.80	
26	7:35		0.85	
27	6:48		0.86	
28	6:58		0.85	
29	8:38		0.84	
30	7:11		0.84	
31	7:14	WTP - A1	0.83	

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L  NO  
 If yes, what was the longest time period until the required level was restored \_\_\_\_ hours - if > 4 hours,  
 Drinking Water Program to be notified by end of next business day

**GWS Servin 3,300 or Fewer**  
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO  
*Attach those results and submit them with this form*

**Printed Name** Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

**Signature** *Stephen Sagmiller*

**Date** \_\_\_\_ 2/7/2024