

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Feb-24 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	6:57	WTP - A1		0.82
2	7:22			0.80
3	10:45			0.82
4	8:45			0.82
5	7:55			0.82
6	7:05			0.74
7	7:26			0.74
8	7:23			0.82
9	8:35			0.84
10	8:05			0.78
11	7:45			0.83
12	7:22			0.85
13	7:30			0.83
14	7:33			0.83
15	7:35			0.81
16	8:26			0.81
17	8:00			0.86
18	7:45			0.85
19	8:00			0.86
20	7:20			0.82
21	7:05			0.84
22	7:10			0.88
23	8:53			0.82
24	8:23			0.82
25	9:47			0.82
26	7:28			0.82
27	7:29			0.82
28	7:45			0.83
29	7:48			0.82
		WTP - A1		

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next buisness day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
 Attach those results and submit them with this form

Printed Name Stephen Sagmiller **Title**Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 3/5/2024

