

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton PWS # 4100252  
 Month/Year Mar-24 Entry Point WTP - A1 Required Minimum Residual 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	8:23	WTP - A1		0.85
2	8:19			0.90
3	8:06			0.86
4	7:11			0.90
5	7:12			0.87
6	7:00			0.85
7	7:30			0.88
8	8:00			0.86
9	7:45			0.85
10	9:00			0.84
11	7:15			0.82
12	7:25			0.84
13	7:00			0.85
14	7:15			0.80
15	9:38			0.93
16	8:44			0.83
17	9:52			0.81
18	7:26			0.83
19	7:24			0.80
20	7:28			0.82
21	7:31			0.83
22	9:05			0.81
23	7:30			0.84
24	7:40			0.76
25	7:15			0.82
26	7:10			0.82
27	7:10			0.85
28	7:10			0.82
29	7:15			0.81
30	7:59			0.88
31	7:59	WTP - A1		0.81

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L  NO  
 If yes, what was the longest time period until the required level was restored \_\_\_ hours - if > 4 hours,  
 Drinking Water Program to be notified by end of next buisness day

**GWS Servin 3,300 or Fewer**  
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO  
 Attach those results and submit them with this form

Printed Name Stephen Sagmiller Title Public Works Director Operator Certification # 6845

Signature *Stephen Sagmiller*

Date \_\_\_ 4/7/2024