

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Apr-24 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	7:23	WTP - A1		0.91
2	10:50			0.87
3	7:27			0.87
4	8:15			0.81
5	7:15			0.80
6	7:50			0.87
7	7:40			0.88
8	7:05			0.82
9	7:05			0.86
10	7:20			0.82
11	7:10			0.82
12	7:30			0.83
13	7:00			0.85
14	7:10			0.81
15	8:00			0.83
16	7:30			0.84
17	7:30			0.79
18	7:10			0.80
19	7:47			0.85
20	6:48			0.81
21	7:00			0.89
22	7:35			0.84
23	7:30			0.84
24	8:15			0.95
25	7:34			0.92
26	8:08			0.84
27	7:55			0.77
28	7:58			0.82
29	7:29			0.81
30	7:31			0.79
		WTP - A1		

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

--

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 5/1/2024