

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year May-24 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	7:28	WTP - A1		0.81
2	7:35			0.80
3	8:25			0.85
4	7:15			0.82
5	6:30			0.83
6	7:30			0.82
7	7:02			0.83
8	7:45			0.82
9	9:01			0.82
10	8:35			0.78
11	7:25			0.85
12	7:13			0.82
13	6:33			0.83
14	7:15			0.80
15	7:20			0.78
16	8:41			0.82
17	7:40			0.81
18	6:57			0.73
19	7:57			0.70
20	7:35			0.76
21	7:30			0.80
22	7:38			0.85
23	7:21			0.81
24	7:30			0.85
25	7:27			0.82
26	7:22			0.82
27	7:50			0.86
28	7:05			0.85
29	7:03			0.82
30	7:10			0.87
31	7:45	WTP - A1		0.81

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

Printed Name Stephen Sagmiller **Title**Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 6/3/2024