

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Jun-24 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	7:00	WTP - A1		0.83
2	7:15			0.84
3	8:15			0.85
4	7:15			0.80
5	7:20			0.83
6	7:30			0.79
7	8:32			0.73
8	7:48			0.86
9	11:00			0.82
10	7:10			0.93
11	7:06			0.80
12	7:15			0.88
13	7:08			0.81
14	8:00			0.83
15	7:10			0.82
16	7:35			0.82
17	7:10			0.82
18	7:10			0.82
19	7:40			0.89
20	7:15			0.82
21	7:40			0.83
22	8:07			0.79
23	7:52			0.78
24	7:32			0.76
25	7:25			0.75
26	7:22			0.72
27	8:05			0.83
28	8:00			0.84
29	9:00			0.79
30	8:30			0.83
		WTP - A1		

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 7/2/2024