

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton **PWS #** 4100252
Month/Year Sep-24 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	7:50	WTP - A1		0.83
2	7:55			0.84
3	7:37			0.81
4	7:42			0.83
5	7:19			0.87
6	8:17			0.86
7	10:00			0.87
8	8:20			0.84
9	7:38			0.84
10	7:18			0.81
11	7:24			0.85
12	7:29			0.86
13	7:29			0.87
14	7:55			0.87
15	8:01			0.88
16	7:38			0.88
17	7:37			0.88
18	7:51			0.86
19	7:26			0.85
20	6:30			0.84
21	9:57			0.86
22	10:30			0.86
23	7:27			0.85
24	7:22			0.86
25	7:28			0.83
26	8:25			0.84
27	8:24			0.84
28	7:57			0.84
29	8:08			0.84
30	7:29			0.84
		WTP - A1		

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next business day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
Attach those results and submit them with this form

Printed Name Stephen Sagmiller **Title** Public Works Director **Operator Certification #** 6845

Signature *Stephen Sagmiller*

Date ____ 10/2/2024