

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Dayton PWS # 4100252
 Month/Year Oct-24 Entry Point WTP - A1 Required Minimum Residual 0.6 mg/L

Lowest free chlorine residual at entry point to distribution system				
Date	Time	Source in Use	system	Notes
1	9:00	WTP - A1		0.85
2	8:15			0.87
3	8:40			0.84
4	9:20			0.85
5	8:13			0.86
6	8:15			0.87
7	8:50			0.87
8	7:43			0.87
9	7:47			0.85
10	7:54			0.84
11	7:30			0.78
12	10:30			0.86
13	8:19			0.87
14	7:15			0.88
15	7:39			0.87
16	7:59			0.86
17	8:44			0.86
18	7:45			0.83
19	8:00			0.84
20	6:30			0.84
21	7:45			0.81
22	6:30			0.77
23	7:57			0.84
24	7:45			0.83
25	8:18			0.88
26	8:20			0.88
27	8:29			0.88
28	7:36			0.88
29	8:37			0.89
30	9:31			0.86
31	7:21	WTP - A1		0.87

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO
 If yes, what was the longest time period until the required level was restored ___ hours - if > 4 hours,
 Drinking Water Program to be notified by end of next buisness day

GWS Servin 3,300 or Fewer
 If yes, did you monitor every 4 hours until the residual returned to 0.6 mg/L as required YES NO
 Attach those results and submit them with this form

Printed Name Stephen Sagmiller Title Public Works Director Operator Certification # 6845

Signature *Stephen Sagmiller*

Date ___ 11/5/2024

