

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

**System Name** City of Dayton **PWS #** 4100252  
**Month/Year** Dec-24 **Entry Point** WTP - A1 **Required Minimum Residual** 0.6 mg/L

			Lowest free chlorine residual at entry point to distribution system	
Date	Time	Source in Use		Notes
1	7:33	WTP - A1	0.72	
2	7:32		0.69	
3	7:20		0.75	
4	7:19		0.76	
5	7:12		0.9	
6	8:49		0.76	
7	7:55		0.69	
8	7:56		0.75	
9	7:39		0.76	
10	8:56		0.76	
11	7:53		0.66	
12	9:15		0.71	
13	7:25		0.73	
14	6:55		0.78	
15	7:45		0.79	
16	7:50		0.81	
17	7:39		0.82	
18	7:45		0.73	
19	8:33		0.75	
20	8:39		0.74	
21	7:49		0.72	
22	7:51		0.86	
23	7:20		0.89	
24	7:38		0.64	
25	7:32		0.65	
26	7:10		0.62	
27	7:25		0.79	
28	9:10		0.87	
29	8:20		0.82	
30	7:42	WTP - A1	0.73	
	7:36		0.68	

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO

If yes, what was the longest time period until the required level was restored \_\_\_\_ hours - if > 4 hours,

Drinking Water Program to be notified by end of next buisness day

**GWS Servin 3,300 or Fewer**

If yes, did you monitor every 4 hours  
until the residual returned to 0.6 mg/L  
as required YES NO

*Attach those results and submit them  
with this form*

**Printed Name** Don Cutler **Title** Public Works Supervisor **Operator Certification #** 2853  
**DRC - Darrel Lockard**

**Signature** Don Cutler

**Date** \_\_\_\_ 1/6/2025