

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name

City of Dayton

PWS # 4100252

Month/Year

July-25



Entry Point WTP - A1

Required Minimum Residual 0.6 mg/L

Lowest free chlorine residual at entry point to distribution				
Date	Time	Source in Use	system	Notes
1	6:56	WTP - A1	1.03	
2	8:23		1.05	
3	9:00		1.1	
4	7:43		0.81	
5	8:02		0.83	
6	7:40		0.83	
7	7:51		0.76	
8	7:43		0.92	
9	7:42		0.91	
10	7:41		0.95	
11	8:21		0.81	
12	8:14		0.81	
13	8:01		0.82	
14	7:38		0.78	
15	6:45		0.8	
16	7:30		0.81	
17	7:20		0.82	
18	8:04		0.82	
19	8:01		0.8	
20	8:43		0.81	
21	8:20		0.82	
22	6:36		0.81	
23	6:44		0.82	
24	7:03		0.81	
25	8:09		0.81	
26	7:47		0.8	
27	8:10		0.81	
28	7:50		0.81	
29	7:18		0.83	
30	7:11	WTP - A1	0.81	
31	7:07		0.81	

Was the chlorine residual ever less than the required minimum residual of 0.6 mg/L NO

If yes, what was the longest time period until the required level was restored ____ hours - if > 4 hours,

Drinking Water Program to be notified by end of next buisness day

GWS Servin 3,300 or Fewer

If yes, did you monitor every 4 hours
until the residual returned to 0.6 mg/L
as required YES NO

*Attach those results and submit them
with this form*

Printed Name Don Cutler

Title Public Works Supervisor

Operator Certification # 149310

DRC – John Lindow

Signature Don Cutler

Date ____ 9/3/2025