

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name City of Dundee

PWS ID# 4 1 00262

Month/Year  June/2025

Entry Point: EP-A

Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	0730	1,2,7,8,11	1.55	
2	0920	1,2,7,8,11	1.11	Add CL2
3	0835	1,2,7,8,11	0.72	
4	1050	1,2,7,8,11	0.59	
5	1150	1,2,7,8,11	0.61	
6	1125	1,2,7,8,11	0.83	
7	0915	1,2,7,8,11	1.22	
8	0925	1,2,7,8,11	0.85	
9	0830	1,2,7,8,11	0.80	Add CL2
10	0912	1,2,7,8,11	1.08	
11	0945	1,2,7,8,11	0.72	
12	1230	1,2,7,8,11	0.85	
13	1315	1,2,7,8,11	0.91	
14	0935	1,2,7,8,11	0.94	
15	0930	1,2,7,8,11	0.95	
16	1000	1,2,7,8,11	0.87	
17	1015	1,2,7,8,11	0.80	
18	1020	1,2,7,8,11	0.76	
19	1025	1,2,7,8,11	0.65	
20	1010	1,2,7,8,11	0.68	
21	0940	1,2,7,8,11	0.80	
22	0920	1,2,7,8,11	0.77	
23	1330	1,2,7,8,11	0.95	Add CL2
24	1100	1,2,7,8,11	0.69	
25	0950	1,2,7,8,11	0.66	
26	1230	1,2,7,8,11	0.69	
27	1230	1,2,7,8,11	0.73	
28	0850	1,2,7,8,11	0.79	
29	1100	1,2,7,8,11	0.65	
30	1202	1,2,7,8,11	0.74	
31	0840	1,2,7,8,11	0.68	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to 0.20 mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Jared Nunley

Title: Drinking Water DRC

Operator Certification #: T-08400

Signature: \_\_\_\_\_

Phone #: (503) 538-6700

OR

Date: 8 / 4 / 2025

Small Groundwater System ☒