

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems


System Name: Seavey Loop Water Company **PWS ID#** 41 - 00289

Month/Year: December-21 **Required Minimum Residual:** 0.30 mg/L

Date	Time	Source(s) in Use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	2:00:00 PM	WELL (L16262)	0.41	
2	10:00:00 AM	WELL (L16262)	0.49	
3	10:00:00 AM	WELL (L16262)	0.45	
4	10:00:00 AM	WELL (L16262)	0.41	
5	6:00:00 AM	WELL (L16262)	0.42	
6	2:00:00 PM	WELL (L16262)	0.43	
7	10:00:00 AM	WELL (L16262)	0.50	
8	6:00:00 AM	WELL (L16262)	0.56	
9	6:00:00 PM	WELL (L16262)	0.34	
10	6:00:00 PM	WELL (L16262)	0.52	
11	6:00:00 PM	WELL (L16262)	0.47	
12	6:00:00 PM	WELL (L16262)	0.38	
13	10:00:00 AM	WELL (L16262)	0.54	
14	10:00:00 AM	WELL (L16262)	0.41	
15	6:00:00 AM	WELL (L16262)	0.51	
16	2:00:00 PM	WELL (L16262)	0.62	
17	2:00:00 PM	WELL (L16262)	0.51	
18	6:00:00 AM	WELL (L16262)	0.48	
19	6:00:00 AM	WELL (L16262)	0.50	
20	6:00:00 PM	WELL (L16262)	0.52	
21	10:00:00 AM	WELL (L16262)	0.47	
22	10:00:00 AM	WELL (L16262)	0.43	
23	2:00:00 PM	WELL (L16262)	0.53	
24	6:00:00 AM	WELL (L16262)	0.56	
25	6:00:00 AM	WELL (L16262)	0.50	
26	6:00:00 AM	WELL (L16262)	0.40	
27	10:00:00 AM	WELL (L16262)	0.47	
28	2:00:00 PM	WELL (L16262)	0.53	
29	2:00:00 PM	WELL (L16262)	0.50	
30	6:00:00 PM	WELL (L16262)	0.53	
31	10:00:00 AM	WELL (L16262)	0.56	

Was the chlorine residual ever less than the required minimum residual of **.30 mg/L** Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to .30 mg/L?</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------

<p>Printed Name: Dan Reitz</p> <p>Signature: </p> <p>Date: 1/6/2022</p>	<p>Title: Vice- President</p> <p>Oregon Water Services, Inc.</p> <p>Phone#: (541) 342-1718</p>	<p>Operator Certification #: 6528</p> <p style="text-align: center;">OR</p> <p style="text-align: center;">Small Ground Water System</p>
---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------