

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

**System Name:** Seavey Loop Water Company **PWS ID#** 41 - 00289

**Month/Year:** January-23 **Required Minimum Residual:** 0.30 mg/L

Date	Time	Source(s) in Use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	2:00:00 PM	WELL (L16262)	0.40	
2	10:00:00 AM	WELL (L16262)	0.33	
3	10:00:00 AM	WELL (L16262)	0.34	
4	10:00:00 AM	WELL (L16262)	0.39	
5	6:00:00 AM	WELL (L16262)	0.41	
6	2:00:00 PM	WELL (L16262)	0.32	
7	10:00:00 AM	WELL (L16262)	0.39	
8	6:00:00 AM	WELL (L16262)	0.39	
9	6:00:00 PM	WELL (L16262)	0.39	
10	6:00:00 PM	WELL (L16262)	0.34	
11	6:00:00 PM	WELL (L16262)	0.35	
12	6:00:00 PM	WELL (L16262)	0.45	
13	10:00:00 AM	WELL (L16262)	0.40	
14	10:00:00 AM	WELL (L16262)	0.56	
15	6:00:00 AM	WELL (L16262)	0.69	
16	2:00:00 PM	WELL (L16262)	0.49	
17	2:00:00 PM	WELL (L16262)	0.42	
18	6:00:00 AM	WELL (L16262)	0.35	
19	6:00:00 AM	WELL (L16262)	0.36	
20	6:00:00 PM	WELL (L16262)	0.36	
21	10:00:00 AM	WELL (L16262)	0.46	
22	10:00:00 AM	WELL (L16262)	0.56	
23	2:00:00 PM	WELL (L16262)	0.60	
24	6:00:00 AM	WELL (L16262)	0.73	
25	6:00:00 AM	WELL (L16262)	0.70	
26	6:00:00 AM	WELL (L16262)	0.72	
27	10:00:00 AM	WELL (L16262)	0.71	
28	2:00:00 PM	WELL (L16262)	0.67	
29	2:00:00 PM	WELL (L16262)	0.62	
30	6:00:00 PM	WELL (L16262)	0.57	
31	10:00:00 AM	WELL (L16262)	0.50	

Was the chlorine residual ever less than the required minimum residual of .30 mg/L  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to .30 mg/L?  <i>Attach those results and submit them with this form.</i></p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No                  If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  <input type="checkbox"/> Yes <input type="checkbox"/> No  <i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed:                  / /</p> <p>Date it was returned to service:                  / /</p>
--	--	---

<p><b>Printed Name:</b> Dan Reitz                  Signature: </p>	<p><b>Title:</b> Vice- President                  Oregon Water Services, Inc.                  Phone#: (541) 342-1718</p>	<p><b>Operator Certification #:</b> 6528                  OR</p> <p style="text-align: center;">Small Ground Water System</p>
<p><b>Date:</b> 2/7/2023</p>		

Hour	Chlorine Residual	
0	0.4638	
1	0.4732	
2	0.5045	
3	0.4559	
4	0.5076	
5	0.5105	
6	0.5241	
7	0.4915	
8	0.4803	
9	0.4785	
10	0.4479	
11	0.355	
12	0.4416	
13	0.5042	
14	0.4792	
15	0.4832	
16	0.4837	
17	0.4712	
18	0.4345	
19		
20		
21		
22		
23		
Average chlorine	0.4792	20-Jan