

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name: City of Florence PWS ID# 4 1 00299  
 Month/Year Janu 2021 Entry Point: EP - A Required Minimum Residual .3 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:30	1,7,12,13	0.69	
2	8:11	1,7,12,13	0.54	
3	23:54	1,7,12,13	0.74	
4	1:29	1,7,12,13	0.5	
5	18:42	1,7,12,13	0.49	
6	0:06	1,7,12,13	0.82	
7	12:01	1,7,12,13	0.53	
8	10:37	1,7,12,13	0.57	
9	4:58	1,7,12,13	0.55	
10	22:21	1,7,12,13	0.55	
11	0:07	1,7,12,13	0.79	
12	16:01	1,7,12,13	0.57	
13	23:59	1,7,12,13	0.88	
14	9:37	1,7,12,13	0.61	
15	17:09	1,6,11,13	0.63	
16	0:16	1,6,11,13	0.73	
17	20:29	1,6,11,13	0.55	
18	4:16	1,6,11,13	0.61	
19	13:41	1,6,11,13	0.46	
20	22:35	1,6,11,13	0.6	
21	0:01	1,6,9,11,13	0.85	
22	6:30	1,6,9,11,13	0.7	
23	15:48	1,6,7,11,13	0.55	
24	19:24	1,2,6,9,11,13	0.66	
25	10:46	1,2,6,7,9,11,13	0.83	
26	23:15	1,2,6,7,9,11,13	0.8	
27	23:59	1,2,9,11,13	0.75	
28	3:32	1,2,9,11,13	0.5	
29	14:32	1,9,11,13	0.57	
30	23:59	1,2,9,11,13	0.52	
31	0:12	1,2,9,11,13	0.47	

Was the chlorine residual ever less than the required minimum residual of 0.3 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_ hours

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to 0.3 mg/L? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them</i></p>	<p style="text-align: center;"><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>
	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>

Printed Name: August Murphy	Title: WTP DRC	Operator Certification #: T 08399
Signature: <i>August Murphy</i>	Phone #: (541) 997-7370	OR
Date: 2 / 2 / 2021		Small Groundwater System