

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name: City of Florence PWS ID# 4 1 00299
 Month/Year March / 2021 Entry Point: EP - A Required Minimum Residual .3 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	6:24	1,6,11,13	0.45	
2	19:07	1,6,11,13	0.41	
3	23:51	1,6,11,13	0.59	
4	0:28	1,6,11,13	0.59	
5	23:40	1,6,11,13	0.62	
6	21:38	1,6,11,13	0.61	
7	19:59	1,6,11,13	0.58	
8	18:05	1,6,11,13	0.56	
9	16:00	1,6,11,13	0.56	
10	13:58	1,6,11,13	0.57	
11	11:36	1,6,11,13	0.57	
12	9:17	1,6,11,13	0.57	
13	12:20	5,11	0.38	
14	15:42	5,11	0.56	
15	18:44	5,11	0.45	
16	16:38	5,11	0.53	
17	12:55	5,11	0.55	
18	8:09	5,11	0.6	
19	18:27	2,3,4,5	0.81	
20	16:24	2,3,4,5	0.53	
21	13:45	2,3,4,5	0.81	
22	3:10	2,3,4,5	0.84	
23	4:52	2,3,4,5	0.86	
24	12:35	2,3,4,5	0.91	
25	21:17	2,3,4,5	0.65	
26	15:48	2,3,4,5	0.94	
27	9:51	2,3,4,5	0.85	
28	20:18	2,3,4,5	0.82	
29	4:06	2,3,4,5	0.79	
30	7:59	2,3,4,5	0.8	
31	19:27	2,3,4,5	0.66	

Was the chlorine residual ever less than the required minimum residual of 0.3 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? ___ hours

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to 0.3 mg/L? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this</i></p>	<p style="text-align: center;">GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>
	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>

Printed Name: August Murphy	Title: WTP DRC	Operator Certification #: T 08399
Signature: <i>August Murphy</i>	Phone #: (541) 997-7370	OR
Date: 4 / 2 / 2021		Small Groundwater System