

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name LAUREL WOOD WATER USERS CO-OP PWS ID# 41 00315
 Month/Year 07/21 Entry Point: SPRING Required Minimum Residual 20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:03A	LAUNDRY ROOM	.66	
2	7:27A	"	.65	
3	7:10A	"	.74	
4	7:46A	"	.73	
5	6:46A	"	.59	
6	8:29A	"	.66	
7	9:40A	"	.74	
8	8:16A	"	.71	
9	7:08A	"	.79	
10	7:51A	"	.76	
11	6:05A	"	.79	
12	7:39A	"	.74	
13	7:05A	"	.70	
14	11:05A	"	.63	
15	8:04A	"	.68	
16	6:29A	"	.66	
17	2:05P	"	.68	
18	7:39	"	.71	
19	6:20A	"	.82	
20	7:00A	"	.97	
21	6:40A	"	.72	
22	8:10A	"	.90	
23	7:47A	"	.73	
24	8:00A	"	.81	
25	7:04A	"	.68	
26	7:20A	"	.85	
27	8:00A	"	.74	
28	7:20A	"	.80	
29	8:00A	"	.82	
30	8:00	"	.88	
31	3:10P	Bathroom Tub	.57	

Was the chlorine residual ever less than the required minimum residual of 20 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____/_____/_____ Date it was returned to service: _____/_____/_____</p>
--	--	---

Printed Name: JANE RUSSELL Title: _____ Operator Certification #: _____
 Signature: Jane Russell Phone #: (503) 203-7378 OR
 Date: 08/02/21 Small Groundwater System