

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name LAURELWOOD WATER USERS Co-op PWS ID# 41 00315
 Month/Year 12/21 Entry Point: So Springs Required Minimum Residual .2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:40A	LAUNDRY ROOM	.57	
2	8:44A	"	.60	
3	9:17A	"	.55	
4	10:54A	"	.54	
5	10:20A	"	.54	
6	9:56A	"	.59	
7	8:20A	"	.51	
8	9:55A	"	.54	
9	10:05A	"	.53	
10	8:37	"	.50	
11	10:10A	"	.50	
12	9:15A	"	.43	
13	9:00A	"	.44	
14	8:17A	"	.39	
15	8:35A	"	.49	
16	9:25A	"	.47	
17	8:20A	"	.47	
18	8:39A	"	.35	
19	9:15A	"	.36	
20	8:33A	"	.43	
21	8:08A	"	.36	
22	7:50A	"	.34	
23	7:00A	"	.35	
24	7:50A	"	.39	
25	8:10A	"	.36	
26	7:57A	"	.36	
27	8:37A	"	.42	
28	7:20A	"	.48	
29	8:15A	"	.44	
30	10:58A	"	.39	
31	8:40A	"	.39	

Was the chlorine residual ever less than the required minimum residual of .2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____/_____/_____</p> <p>Date it was returned to service: _____/_____/_____</p>
--	--	---

Printed Name: JANE RUSSELL Title: _____ Operator Certification #: _____
 Signature: Jane Russell Phone #: (503) 703 7378
 Date: 12/31/21

OR
Small Groundwater System