

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name LAURELWOOD WATER USERS COOP PWS ID# 41 00315
 Month/Year 04/22 Entry Point: _____ Required Minimum Residual 2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:20A	LAUNDRY ROOM	.69	
2	7:54A		.49	
3	8:10		.85	
4	8:20		.86	
5	7:51A		.85	
6	8:26A		.51	
7	2:22P		.50	
8	7:46A		.51	
9	9:05A		.53	
10	8:09A		.56	
11	6:45A		.56	
12	7:48A		.74	.60
13	7:50		.78	
14	8:32A		.60	
15	7:20		.49	
16	7:10		.50	
17	9:05A		.52	
18	10:56A		.47	
19	9:05A		.49	
20	8:07A		.50	
21	8:15A		.46	
22	9:07A		.53	
23	7:37A		.46	
24	8:15A		.53	
25	9:46A		.54	
26	7:48A		.49	
27	7:23A		.50	CLEARLY BACTERIA TEST submitted
28	9:20A		.56	
29	7:57A		.55	
30	7:36A		.45	
31				

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
	<p>Date continuous monitoring equipment failed: _____/_____/_____ Date it was returned to service: _____/_____/_____</p>

Printed Name: JANE RUSSELL Title: _____ Operator Certification #: _____
 Signature: Jane Russell Phone #: (503) 702-7378
 Date: 05/01/22

OR
Small Groundwater System