

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name LAURELWOOD WATER USERS COOP PWS ID# 41 00315
 Month/Year 02 123 Entry Point: _____ Required Minimum Residual .2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:26A	LAUNDRY ROOM	.90	
2	9:23A	"	.85	
3	8:26A	"	.93	
4	9:31A	"	.79	
5	8:45A	"	.90	
6	7:57A	"	.87	
7	7:53A	"	.84	
8	8:36A	"	1.00	
9	7:10A	"	1.05	
10	8:16	"	1.07	
11	7:52A	"	.97	
12	8:16A	"	1.12	
13	7:06A	"	1.10	
14	8:45A	"	1.12	
15	8:01A	"	.92	
16	8:13A	"	.89	
17	8:02A	"	.83	
18	7:25A	"	1.06	
19	7:57A	"	.96	
20	8:34A	"	.91	
21	9:00A	"	1.09	
22	8:06A	"	.95	SNOW
23	8:02A	"	.93	"
24	7:34A	"	.81	"
25	11:00A	"	.78	"
26	8:05A	"	.75	
27	9:21A	"	.72	BACTEST
28	8:52A	"	.65	
29	7:50A	"	.72	
30				
31				

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
<p>Date continuous monitoring equipment failed: _____/_____/_____ Date it was returned to service: _____/_____/_____</p>	

Printed Name: JANE RUSSELL Title: _____ Operator Certification #: _____
 Signature: Jane Russell Phone #: (503) 703 7378 OR
 Date: 02/02/23 Small Groundwater System