

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name LAURELWOOD WATER USERS Co-op PWS ID# 41 00315

Month/Year 06 123 Entry Point _____ Required Minimum Residual .2 mg/L

Date	Time	Source(s) in use <u>LAUNDRY ROOM</u>	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:46A	"	.91	
2	6:44A	"	.71	
3	7:30A	"	.71	
4	6:39A	"	.68	
5	7:57A	"	.68	
6	7:50A	"	.86	
7	8:20A	"	.88	
8	6:52A	"	.76	
9	7:45A	"	.74	
10	6:32A	"	.74	
11	7:53A	"	.80	
12	9:18A	"	.80	
13	7:36A	"	.81	
14	8:38P	"	1.11	
15	1:10 pm	"	1.11	
16	6:70A	"	1.02	
17	7:18A	"	1.02	
18	6:45A	"	1.02	
19	7:45A	"	.91	
20	6:24A	"	.94	
21	7:13A	"	.71	
22	6:42A	"	.84	
23	6:10A	"	.80	
24	7:05A	"	.70	
25	7:13A	"	.90	
26	6:28A	"	.89	
27	6:31A	"	1.01	
28	7:14A	"	.97	
29	6:04	"	.85	
30	7:42A	"	.85	
31				

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____/_____/____</p> <p>Date it was returned to service: _____/_____/____</p>
--	--	---

Printed Name: JANE RUSSELL Title: _____ Operator Certification #: _____
 Signature: Jane Russell Phone #: (503) 709-7378 OR
 Date: 07/01/23 Small Groundwater System