

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name LAURELWOOD WATER USERS COOP PWS ID# 41 00315  
 Month/Year 2 124 Entry Point \_\_\_\_\_ Required Minimum Residual 2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	6:10A		.96	
2	6:07A		1.7	
3	1:42 Pm		1.01	
4	7:54A		.88	
5	7:58A		.77	
6	8:18A		.77	
7	7:40A		.41	
8	8:02A		1.67	
9	8:00A		1.66	
10	7:56A		.73	
11	7:35A		.71	
12	7:53A		.76	
13	7:46A		.73	
14	7:38A		.82	
15	7:24 A		.64	
16	7:06A		.60	
17	6:46A		.59	
18	7:11A		.79	
19	7:52A		.76	
20	7:09A		.72	
21	7:45A		.70	
22	7:58A		.64	
23	8:56a		.71	
24	6:35A		.72	
25	12:13 Pm		.71	
26	7:47A		.63	
27	7:00A		.65	
28	7:00a		.58	
29	7:07A		.72	
30	8:05A		.43	
31	9:06A		.44	

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p align="center"><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____</p> <p>Date it was returned to service: _____</p>
--	---	---

Printed Name: JANE RUSSELL Title: \_\_\_\_\_ Operator Certification #: \_\_\_\_\_  
 Signature: Jane Russell Phone #: (503) 703 7378  
 Date: 03/01/124 OR  
 Small Groundwater System